



NOTES:

- 1) ANCHORS SHALL BE INSTALLED ACCORDING TO MANUFACTURER'S SPECIFICATIONS
- 2) POSTS SHALL BE HOT DIP GALVANIZED ACCORDING TO CSA G164 AFTER FABRICATION
- 3) POSTS SHALL BE VERTICAL. ALL EXPOSED CORNERS SHALL BE GROUND SMOOTH.
- 4) WELDING SHALL BE ACCORDING TO CSA W59
- 5) ALL JOINTS SHALL BE SHOP WELDED
- 6) PIPE SHALL BE ACCORDING TO ASTM A 53
- 7) LOCATE RACK A MINIMUM OF 0.9 m FROM OBSTACLES PARALLEL TO RACK
- 8) LOCATE RACK A MINIMUM OF 2.5 m FROM MAJOR OBSTACLES (EG. WALLS) ON AT LEAST ONE SIDE TO ALLOW EASY ACCESS FOR CYCLIST
- 9) LOCATE RACK A MINIMUM OF 1.2 m FROM OBSTACLES PERPENDICULAR TO RACK ON SIDES NOT ACCESSED BY CYCLIST

ANCHORING SURFACE OPTIONS

- 10) EMBED IN CONCRETE
- 11) ANCHOR TO EXISTING CONCRETE
- 12) POUR CONCRETE PAD AND ANCHOR TO PAD
- 13) INSTALL PAVING STONE AROUND CONCRETE BASE BLOCK (IN-GROUND) OR OVER CONCRETE PAD (SURFACE MOUNT)

ALL DIMENSIONS ARE IN MILLIMETERS UNLESS OTHERWISE STATED

		ENGINEERING STANDARDS	
TITLE POST AND RING BIKE RACK DETAILS AND SECTIONS			
DWN.	C.P.	DATE	JAN. 2011
REVISED:		 MANAGER, ENGINEERING DIVISION	
SCALE		N. T. S.	
Z:\ENG\Standard Drawings\Std Dwgs\M-115-3.dwg		DWG. NO. M-115-3	